


ASTM F 1951-09B Surface Testing Report

ADA Compliance Testing

Summary of Results

Beneficial Designs, Inc. received a surfacing sample from **Envirobond Products Corporation** classified as Surface stabilizer with the brand name **Organic-Lock**. This sample of Organic-Lock **met** the maneuverability performance requirements of ASTM F 1951-09b

Report Prepared By:



Peter Axelson, Tesing Supervisor

16 July 2014

Date

Test Institution

Name: Beneficial Designs, Inc.

Phone: 775-783-8822

Operator: S. Schorbus

Data recorder: B. Blythe

Rotational Penetrometer

Manufacturer: Beneficial Designs, Inc.

Serial Number: BDRP-107

Test Surface

Manufacturer: Envirobond Products Corporation

Name: Organic-Lock

Type: Surface stabilizer

Test Surface: Installation, Leveling & Compaction

Installed on the test site per manufacturer specifications

Test Results

The test plot of aggregate blended with Organic-Lock, installed per manufacturer specifications had a firmness of 0.170 inches and stability of 0.188 inches